

7631  
d. 30/5/24

**ANDHRA PRADESH STATE LOAD DESPATCH CENTRE**

**From**  
Chief Engineer,  
APSLDC,  
Vidyut Soudha,  
Vijayawada- 520 004.

**To**  
The Executive Director,  
RAC,PLG,EA & IPC,  
APSPDCL,19-13-65/A,  
Vidyut Nilayam, Srinivasapuram,Tirupati.

**APCRDCL**  
**CO VJA**

Director (Tech.)	
Director (Projects)	
Director (Fin.)	
CMD	

30 MAY 2024

The Chief General Manager,  
RAC.PPA & Solar Energy,  
3<sup>rd</sup> Floor,APEPDCL,  
Corporate office,P&T Colony,  
Sethammadhara, Visakhapatnam-530013.

The Chief General Manager,  
RAC,APCPDCL,Corporate office,  
ITI Road,Vijayawada.

<b>DIRECTOR/PROJECTS</b>	
<b>CGM/PROJECTS</b>	Sir
<b>GM/PROJECTS</b>	Sub: APSLDC-Approved Percentage cumulative availabilities/Capacity Index of APGENCO,APPDCL,HNPCL thermal Power stations and APGENCO Hydel stations for FY2023-24 Communicated- Regarding.
<b>GM/PPA&amp;RAC</b>	

LE.No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D.No.222/24,Dt.23.05.2024

116

\*\*\*\*\*

The approved Percentage cumulative availabilities/Capacity Index

<b>CGM (Projects)</b>	
GM	of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations for FY 2023-
EE	24 are attached herewith. It is requested to arrange for placing the availabilities in the
Dy.EE1	Website as per Directive at Para No 128 (i) (page No.100 of 377) of APERC tariff
Dy.EE2	order for the year 2023-24.
Dy.EE3	Encl As above.
Dy.EE4	

Yours faithfully,

*Y.A*  
Chief Engineer/APSLDC

In appropriate  
for n.a.

Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.  
It is requested to arrange for placing the availabilities in the Websites as per Directive at para No 128(i),page No.100 of APERC tariff order for the year 2023-24.  
Copy Communicated to the Chief General Manager/PP&Legal/APPCC/Vidyut Soudha/Vijayawada.

Dy Genl Rce for n/a  
RM  
116

Approved Percentage availabilities/Capacity Index of APGENCO,APPDCL,HNPC Thermal and APGENCO Hydel stations for the Year 2023-24

Station/Month	Thermal Stations										Hydel stations							
	Dr.MVR RTPP Stg-1	Dr.MVR RTPP Stg-2	Dr.MVR RTPP Stg-3	Dr.MVR RTPP Stg-4	Dr. NTTPS Stg. I TO III	Dr. NTTPS Stg -IV	Dr. NTTPS Stg -V	K.Patnam, Stage-1	K Patnam, Stage-2	HNPC	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobi lam	Chettipeta	NSRTail Pond
Apr-23	72.34	98.03	82.15	68.27	87.29	88.22	-	56.70	68.09	56.75	100.00	100.00	100.00	100.00	100.00	-	100.00	100.00
May-23	75.63	94.19	80.30	77.40	87.49	81.14	-	64.50	66.43	72.63	100.00	100.00	100.00	-	-	-	-	100.00
Jun-23	84.08	92.44	74.98	80.44	84.79	95.84	-	49.24	72.75	72.33	100.00	100.00	100.00	-	-	-	100.00	-
Jul-23	75.14	48.18	70.90	77.00	69.21	82.31	-	46.00	45.90	57.99	-	100.00	100.00	100.00	-	-	100.00	-
Aug-23	73.57	89.27	5.70	70.69	65.82	75.25	-	56.50	0.65	61.75	-	100.00	100.00	100.00	-	-	100.00	100.00
Sep-23	69.94	92.30	79.23	61.04	66.01	80.82	-	40.04	5.69	84.14	-	100.00	100.00	100.00	-	-	100.00	-
Oct-23	56.47	90.25	81.05	62.73	70.82	82.35	-	49.98	25.85	85.08	-	99.19	100.00	100.00	-	-	100.00	-
Nov-23	54.82	93.95	86.80	70.69	74.12	76.88	-	24.90	68.46	51.05	-	99.17	100.00	94.70	-	-	100.00	100.00
Dec-23	78.17	53.00	93.54	64.89	58.23	80.60	63.12	38.06	38.69	46.96	100.00	80.65	100.00	100.00	-	-	100.00	100.00
Jan-24	79.92	99.54	97.85	80.19	76.24	85.96	35.71	28.78	41.92	58.41	-	95.55	100.00	100.00	-	-	94.12	100.00
Feb-24	83.10	96.96	88.27	78.05	80.87	80.37	6.76	51.79	56.62	47.16	-	100.00	100.00	100.00	-	-	100.00	100.00
Mar-24	79.44	93.40	85.65	63.56	75.25	87.61	53.82	52.93	68.92	64.98	-	100.00	100.00	100.00	-	-	100.00	100.00
Cumulative up to March 2024 for FY 2023-24	73.54	86.66	77.10	71.22	74.61	83.10	35.94	46.63	46.53	63.33	100.00	97.84	100.00	99.33	100.00	-	99.56	100.00

Y.A. \_\_\_\_\_  
 CHIEF ENGINEER  
 APSLDC, VIDYUT SOUDHA  
 VIJAYAWADA