

3111
dt 22/2/24

ANDHRA PRADESH STATE LOAD DESPATCH CENTRE

From
Chief Engineer,
APSLDC,
Vidyut Soudha,
Gumadara, Vijayawada- 520 004.

To
The Executive Director,
RAC,PLG,EA & IPC,
APSPDCL,19-13-65/A,
Vidyut Nilayam, Srinivasapuram,Tirupati.

The Chief General Manager,
RAC,PPA & Solar Energy,
3rd Floor,APEPDCL,
Corporate office,P&T Colony,
Sethammadhara,Visakhapatnam-530013.

The Chief General Manager,
RAC,APCPDCL,Corporate office,
ITI Road,Vijayawada.

Director (Tech.)	
Director (Projects)	
Director (Fini.)	
CMD	

22 FEB 2024

Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D.No.1203/24,Dt.13.02.2024


Sir,

Sub: APSLDC-Provisional Percentage cumulative availabilities/Capacity Index of APGENCO,APPDCL,HNPCL thermal Power stations and APGENCO Hydel stations upto the month of January 2024 for FY2023-24 Communicated- Regarding.

* * * * *

The provisional percentage cumulative availabilities/Capacity Index of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations up to the month of January 2024 for FY 2023-24 are attached herewith. It is requested to arrange for placing the availabilities in the Website as per Directive at Para No 128 (i) (page No.100 of 377) of APERC tariff order for the year 2023-24.

Encl: As above.

Yours faithfully,

Chief Engineer/APSLDC

Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.
It is requested to arrange for placing the availabilities in the Websites as per Directive at para No 128(i),page No.100 of APERC tariff order for the year 2023-24.
Copy Communicated to the Chief Engineer/Commercial/APGENCO/Vidyut Soudha/Vijayawada.
Copy Communicated to CGM/APPDCL/2nd Floor/APPCC Building /Vidyut Soudha/Vijayawada.
Copy Communicated to the Chief General Manager/Power Purchase/APPCC/Vidyut Soudha/Vijayawada.

CGM (Projects)	
GM/PPA	
EE	
Dy.EE1	
Dy.EE2	
Dy.EE3	
Dy.EE4	

To
EE/PPS,RAC
22/2

Dated Rec
RM
23/2

Provisional Percentage availabilities/Capacity Index of APGENCO Thermal and Hydel stations for the Year 2023-24

Station/Month	Thermal Stations									Hydel stations								
	Dr.MVR RTPP Stg-1	Dr.MVR RTPP Stg-2	Dr.MVR RTPP Stg-3	Dr.MVR RTPP Stg-4	Dr. NTTPS Stg- I TO III	Dr. NTTPS Stg -IV	Dr. NTTPS Stg -V	K.Patnam, Stage-1	K.Patnam, Stage-2	HNPCL	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobi lam	Chettipeta	NSRTail Pond
Apr-23	72.34	98.03	82.15	68.27	87.29	88.22	-	56.70	68.09	56.75	100.00	100.00	100.00	100.00	100.00	-	100.00	100.00
May-23	75.63	94.19	80.30	77.40	87.49	81.14	-	64.50	66.43	72.63	100.00	100.00	100.00	-	-	-	-	100.00
Jun-23	84.08	92.44	74.98	80.44	84.79	95.84	-	49.24	72.75	72.33	100.00	100.00	100.00	-	-	-	100.00	-
Jul-23	75.14	48.18	70.90	77.00	69.21	82.31	-	46.00	45.90	57.99	-	100.00	100.00	100.00	-	-	100.00	-
Aug-23	73.57	89.27	5.70	70.69	65.82	75.25	-	56.50	0.65	61.75	-	100.00	100.00	100.00	-	-	100.00	100.00
Sep-23	69.94	92.30	79.23	61.04	66.01	80.82	-	40.04	5.69	84.14	-	100.00	100.00	100.00	-	-	100.00	-
Oct-23	56.47	90.25	81.05	62.73	70.82	82.35	-	49.98	25.85	85.08	-	99.19	100.00	100.00	-	-	100.00	-
Nov-23	54.82	93.95	86.80	70.69	74.12	76.88	-	24.90	68.46	51.05	-	99.17	100.00	94.70	-	-	100.00	100.00
Dec-23	78.17	53.00	93.54	64.89	58.23	80.60	63.12	38.06	38.69	46.96	100.00	80.65	100.00	100.00	-	-	100.00	100.00
Jan-24	79.92	99.54	97.85	80.19	76.24	85.96	36.39	28.78	41.92	58.41	-	95.55	100.00	100.00	-	-	94.12	100.00
Cumulative up to December 2023 for FY 2023-24	72.03	85.00	75.18	71.35	73.95	82.90	43.39	45.51	43.31	64.69	100.00	97.42	100.00	99.24	100.00	-	99.46	100.00


CHIEF ENGINEER
APSLDC, VIDYUT SOUDHA
VIJAYAWADA