

6332
25/4/24

ANDHRA PRADESH STATE LOAD DESPATCH CENTRE

From
Chief Engineer,
APSLDC,
Vidyut Soudha,
Gundala, Vijayawada- 520-004.

To
The Executive Director,
RAC,PLG,EA & IPC,
APSPDCL,19-13-65/A,
Vidyut Nilayam, Srinivasapuram,Tirupati.

APCPDCL
CO VJA

Director (Tech.)	
Director (Projects)	
Director (Fin.)	
CMD	

The Chief General Manager,
RAC,PPA & Solar Energy,
3rd Floor,APEPDCL,
Corporate office,P&T Colony,
Sethammadhara,Visakhapatnam-530013.

25 APR 2024

The Chief General Manager,
RAC,APCPDCL,Corporate office,
ITI Road,Vijayawada.

25 APR 2024

Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D.No.39 /24,Dt.12 .04.2024

DIRECTOR/PROJECTS APCPDCL	Sir
CGM/PROJECTS	Subj: APSLDC-Provisional Percentage cumulative availabilities/Capacity Index of APGENCO,APPDCL,HNPCL thermal Power stations and APGENCO Hydel stations upto the month of March 2024 for FY2023-24 Communicated- Regarding.
GM/PPA&RAC	

APGENCO,APPDCL,HNPCL thermal Power stations and APGENCO Hydel stations upto the month of March 2024 for FY2023-24 Communicated- Regarding.

The provisional percentage cumulative availabilities/Capacity Index of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations up to the month of March 2024 for FY 2023-24 are attached herewith. It is requested to arrange for placing the availabilities in the Website as per Directive at Para No 128 (i) (page No.100 of 377) of APERC tariff order for the year 2023-24.

Encl: As above.

Yours faithfully,

Y. A. _____
Chief Engineer/APSLDC

Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.
It is requested to arrange for placing the availabilities in the Websites as per Directive at para No 128(i),page No.100 of APERC tariff order for the year 2023-24.
Copy Communicated to the Chief Engineer/Commercial/APGENCO/Vidyut Soudha/Vijayawada.
Copy Communicated to CGM/APPDCL/2nd Floor/APPCC Building /Vidyut Soudha/Vijayawada.
Copy Communicated to the Chief General Manager/Power Purchase/APPCC/Vidyut Soudha/Vijayawada.

EE/PP&RAC
26/4

Dnt BRAC
RM
27/4

29/4
AG/RAE

Provisional Percentage availabilities/Capacity Index of APGENCO Thermal and Hydel stations for the Year 2023-24

Station/Month	Thermal Stations										Hydel stations							
	Dr.MVR RTPP Stg-1	Dr.MVR RTPP Stg-2	Dr.MVR RTPP Stg-3	Dr.MVR RTPP Stg-4	Dr. NTTPS Stg- I TO III	Dr. NTTPS Stg -IV	Dr. NTTPS Stg -V	K.Patnam, Stage-1	K.Patnam, Stage-2	HNPCL	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobi lam	Chettipeta	NSRTail Pond
Apr-23	72.34	98.03	82.15	68.27	87.29	88.22	-	56.70	68.09	56.75	100.00	100.00	100.00	100.00	100.00	-	100.00	100.00
May-23	75.63	94.19	80.30	77.40	87.49	81.14	-	64.50	66.43	72.63	100.00	100.00	100.00	-	-	-	-	100.00
Jun-23	84.08	92.44	74.98	80.44	84.79	95.84	-	49.24	72.75	72.33	100.00	100.00	100.00	-	-	-	100.00	-
Jul-23	75.14	48.18	70.90	77.00	69.21	82.31	-	46.00	45.90	57.99	-	100.00	100.00	100.00	-	-	100.00	-
Aug-23	73.57	89.27	5.70	70.69	65.82	75.25	-	56.50	0.65	61.75	-	100.00	100.00	100.00	-	-	100.00	100.00
Sep-23	69.94	92.30	79.23	61.04	66.01	80.82	-	40.04	5.69	84.14	-	100.00	100.00	100.00	-	-	100.00	-
Oct-23	56.47	90.25	81.05	62.73	70.82	82.35	-	49.98	25.85	85.08	-	99.19	100.00	100.00	-	-	100.00	-
Nov-23	54.82	93.95	86.80	70.69	74.12	76.88	-	24.90	68.46	51.05	-	99.17	100.00	94.70	-	-	100.00	100.00
Dec-23	78.17	53.00	93.54	64.89	58.23	80.60	63.12	38.06	38.69	46.96	100.00	80.65	100.00	100.00	-	-	100.00	100.00
Jan-24	79.92	99.54	97.85	80.19	76.24	85.96	35.71	28.78	41.92	58.41	-	95.55	100.00	100.00	-	-	94.12	100.00
Feb-24	83.10	96.96	88.27	78.05	80.87	80.37	6.76	51.79	56.62	47.16	-	100.00	100.00	100.00	-	-	100.00	100.00
Mar-24	79.44	93.40	85.65	63.56	75.25	87.61	53.82	52.93	68.92	64.98	-	100.00	100.00	100.00	-	-	100.00	100.00
Cumulative up to March 2024 for FY 2023-24	73.54	86.66	77.10	71.22	74.61	83.10	35.94	46.63	46.53	63.33	100.00	97.84	100.00	99.33	100.00	-	99.56	100.00

Y.A. _____
 ✓ CHIEF ENGINEER
 APSLDC, VIDYUT Soudha
 VIJAYAWADA