

11/2023  
dt. 3/8/22  
C.O. VIA

07/09

Director (Tech)	
Director (Fin)	
CMD	

**ANDHRA PRADESH STATE LOAD DESPATCH CENTRE**

**From**  
Chief Engineer,  
APSLDC,  
Vidyut Soudha,  
Gunadala, Vijayawada- 520 004.

**To**  
The Chief General Manager,  
PP, APPCC,  
Vidyut Soudha,  
Gunadala, Vijayawada - 520 004

**Lr. No. CE/SLDC/SE/GO/DEPPMO/DEE2/AEE-PP/F.Avail/D. No.316/22, Dt.25.08.2022**

Sir,

**Sub:** APSLDC-Provisional Percentage cumulative availabilities/Capacity Index of

DIRECTOR (Tech)  
APCPDCL, VJA.

APGENCO, APPDCL thermal Power stations and APGENCO Hydel stations up to the month of July 2022 for 2022-23 Communicated- Regarding.

P&MM	
Projects	
O&M	
IPC	✓
CIVIL	
HRD	
IT&SAP	

\*\*\*\*\*

The provisional percentage cumulative availabilities/Capacity Index of APGENCO ,APPDCL Thermal stations and APGENCO Hydel stations up to the month of July 2022 are attached herewith.

3/8

Encl: As above.

Yours faithfully,

Y-A  
25/8/22  
Chief Engineer/APSLDC (FC)

GM/IPC  
2/8/22

- Copy Communicated to CGM/Commercial/APTRANSCO/Vidyut Soudha/Vijayawada.
- Copy Communicated to Executive Director/RAC & IPC/APSPDCL,19-13-65/A,Vidyut Nilayam, Srinivasapuram,Tirupati..
- Copy Communicated to CGM/IPC,Comml&RAC/APEPDCL/Corporate office/Visakhapatnam.
- Copy Communicated to CGM/IPC,Comml&RAC/APCPDCL/Corporate office/Vijayawada.

\*\*

EE/PPS/RAC  
25/8/22

\*\* It is requested to arrange for placing the availabilities/Capacity Index in the Websites as per Directive at para No 117,page No.80 of APERC tariff order for the year 2022-23.

AT RAC  
copy to AB/PP  
3/8/22

Provisional Percentage availabilities/Capacity Index of APGENCO Thermal and Hydel stations for the Year 2022-23

Station/Month	Thermal Stations							Hydel stations							
	RTPP-1	RTPP-2	RTPP-3	RTPP-4	NTTS I TO III	NTTS-IV	K.Patnam, Stage-1	SSRB	Lower Sileru	Upper Sileru	Donkarayi	NSRC	Pennahobi lam	Chettipeta	NSRTail Pond
Apr-22	87.66	74.13	57.80	72.82	86.98	96.71	47.85	--	100	100	94.77	100	--	100	100
May-22	70.70	81.36	81.72	73.72	81.99	94.19	41.20	--	99.14	100	99.96	100	--	--	100
Jun-22	64.10	94.46	85.19	58.79	73.28	98.05	25.66	--	100	100	100	100	--	100	71.03
Jul-22	37.92	93.41	84.90	70.72	66.21	48.56	43.90	99.64	100	100	100	100	--	100	80.7
Cumulative for 2022-23	64.92	85.87	77.50	69.06	77.07	84.16	39.70	99.64	99.75	100	98.45	100	--	100	84.94

Y. A. →  
 CHIEF ENGINEER (FAC)  
 APSLDC, VIDYUT SOUDHA  
 VIJAYAWADA